

July 5, 2006

DEPARTMENT OF COMMERCE
SAFETY AND BUILDINGS
LYNITA DOCKEN
4003 N KINNEY COULEE RD
LA CROSSE WI 54650

Re: Description: FAUCET, ENVIRONMENTAL SUICIDE PREVENTION
Manufacturer: DEPARTMENT OF COMMERCE
Product Name: SPOUT & ACTION COMBINATION for PSYCHIATRIC CARE FACILITIES
Model Number(s): NONE
Product File No: 20060306

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 82.50(2)(b) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2011.

This alternate approval is contingent upon compliance with the following stipulation(s):

- Neither the spout nor action creates a cross connection situation.
- This alternate spout and action combination is only permitted to vary from s. Comm 82.50 (2) (b) when utilized within psychiatric care facilities where patient safety is at risk when standard goose neck spouts and actions are installed.
- The faucet spouts and actions must comply with the Department of Health and Family Service's standards for environmental suicide prevention.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

James H. Miller
Section Chief, Bureau of Integrated Services
Phone: 608-266-8072 Fax: 608-267-956